

Project description

Degree of protection test acc. to EN 60529, protection code IP65.

Test objects

Sample 1: WS800P x incl. on-wall mounted box
Sample 2: WS203P x CM incl. in-wall mounted box
Sample 3: WS800F x incl. on-wall mounted box
Sample 4: WS212V x CM incl. on-wall mounted box
Sample 5: Combination Sample 1 and 3 incl. on-wall mounted box and chuck connectors

Date of delivery: 30.11. 2009

Date of test performance: 30.11. 2009 – 4.12.2009

Test apparatus

Dust Test Chamber FRIBORG 6800
Water jet propulsion test equipment acc. to EN60529


Test result

No ingress of water or dust could be determined inside the housings of all samples.
The test according to the protection code IP 65 was passed.

Project Engineer

Head of Business Unit


.....


.....